(3 Hours) [Total Marks: 80]

- N.B.: (1) Question No. 1 is compulsory.
 - (2) Answer any three from the remaining five questions.
 - (3) Assumptions made if any should be justified.
 - (4) Use of Refrigerant Charts, Psychrometric Chart, Friction Chart and Steam Tables are allowed.
 - 1. Answer any four of the following.

[20]

[04]

- a) Draw simple vapour compression cycle on P-h diagram and explain the processes.
- b) What are non conventional refrigeration systems? Explain any one type.
- c) Air at T_{db} =30°C and RH=40% undergoes a constant humidity process until the final state is 20°C. Find i)Enthalpy of air at final state. ii)Cooling produced by the coil if the air flow is 200 CMM.
- d) List down types of aircraft refrigeration systems. Draw simple air cooling systems with neat schematic and T-s diagram.
- e) What is human comfort? Explain with help of ASHRAE Comfort chart..
- f) What are primary and secondary refrigerants? Gives examples with application of each type.
- 2. a) A bootstrap air refrigeration system of 30 TR capacity is used for an aeroplane [12] flying at an altitude of 2000 m. The ambient air pressure and temperature are 0.8 bar and 0 C. The ram air pressure and temperature are 1.05 bar and 17 C. The pressure of air after isentropic compression in the main compressor is 4 bar. This air is now cooled to 27 C in another auxillary heat exchanger and then expanded isentropically upto the cabin pressure of 1.01 bar. If the air leaves the cabin at 25 C and the efficiencies for the main compressor, auxillary compressor and the cooling turbine are 80 %, 75 % and 80 % respectively; find: i) Power required to operate the system and ii. COP of the system
 - b) Classify refrigeration compressors. Explain each type in brief. [08]
- 3. a) Define the terms DBT, WBT, DPT and RH.
 - b) What are the different types of Cooling Towers? Explain in brief.Define Range and Approach. [06]
 - c) Draw a neat diagram of Electrolux vapour absorption refrigeration system and explain its working. [10]
- 4. a) A vapour compression system using Ammonia works between -25 °C and [12] 40 °C as evaporator and condenser temperature respectively. Using P-h Chart, determine

69129 Page **1** of **2**

Paper / Subject Code: 53303 / Refrigeration & Air Conditioning

i) COP ii) Mass of refrigerant per TR	2000
iii) Piston displacement per TR using volumetric efficiency = 83 %	2000 V
iv) Heat rejected in the condenser per TR	
v) Ideal COP	
b). Draw a neat sketch of Year Round Air Conditioning system and explain working of its components.	[08]
5. a) What are the sources of cooling load for a Restaurant? Discuss in details.	[06]
b) Define body temperature regulation and effects of extremes of hot and cold climate on human body.	[06]
d) A sling psychrometer reads 40 0 C DBT and 28 0 C WBT when atmospheric pressure is 750 mm of Hg.	[08]
Calculate using Steam Tables only i). Specific humidity ii). Relative humidity	2/2/6°
iii). Dew point temperature iv). Enthalpy	7
6. Write short notes on any four.	[20]
a) Liquefaction of Gases	
b) Duct Design Methods	
c) Desirable Properties of Refrigerants	
d) Thermoelectric Refrigeration	
e) Star Rating of Air Conditioners	
f) DART rating of Air Refrigeration Systems	
\$\times \times \	

69129 Page 2 of 2